

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 10/4/24

It is certified that an inspection team headed by Dr. R. S. Singh

(Name of Officers with designation) from DOCTOR, Medical Officer PHED

inspected the ZEALOT PUBLIC SCHOOL, ALAPUR ROAD, BUDAUN.

(Name & Address of the school) on 10/04/2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. 09 dated 10/04/2024

of JAL NIGAM, BUDAUN (PHED Lab) certified that the

ZEALOT PUBLIC SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 9/04/25

Signature with Seal: चिकित्साधिकारी

Name

Designation: ज्योति. प्रो. स्वा. के. न.

Name & Address of the Officer/ Department: जिला प्रशासन

To ZEALOT PUBLIC SCHOOL
ALAPUR ROAD, BUDAUN.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**कार्यालय अधिशासी अभियन्ता,
खण्ड कार्यालय, उत्तर प्रदेश जल निगम (ग्रामीण),
बदायूँ।**

मा० कांशीराम आवसीय कालोनी के पीछे, ग्राम- खेड़ा बुजुर्ग, बदायूँ-243601

E-mail - eejalnigambudaun@gmail.com

पत्रांक

392

/ 14-11

/ 32

दिनांक

10/04/24

सेवा में,

जीलॉट पब्लिक स्कूल,
जगत बदायूँ।

विषय :- प्रेषित किये गये जल नमूने की जाँच के सम्बन्ध में।

महोदय,

उपरोक्त विषयक आपके कार्यालय पत्रांक-2023-2024 दिनांक 08/04/2024 के द्वारा 01 नग जल नमूने जीलॉट पब्लिक स्कूल, बदायूँ। आप द्वारा जनपदीय प्रयोगशाला उ० प्र० जल निगम (ग्रामीण), बदायूँ पर उपलब्ध कराये गये जल नमूने की Chemical व Bacteriological जाँच कर ली गई है। जाँच रिपोर्ट निर्धारित प्रारूप पर संलग्न कर प्रेषित है।

संलग्नक- जाँच रिपोर्ट।

भवदीय


अधिशासी अभियन्ता

पृ०सं० एवं दिनांक- उपरोक्तानुसार

प्रतिलिपि- निम्नलिखित को सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित।

1 सहायक अभियन्ता/जू०ई० (लैब) प्रयोगशाला, बदायूँ।

Executive Engineer
Division Office
अधिशासी अभियन्ता

WATER ANALYSIS REPORT

District Level Water Analysis Laboratory U.P. Jal Nigam (Rural), Budaun

Report No.	09	Date	10/04/2024	Page No	01
------------	----	------	------------	---------	----

Customer Details

Name & Address	Zealot Public School District Budaun Up.
Reference Letter No. & Date	620/011-Prayogshala/23 Dated 09/5/2023

Basic Details of the Sample

District	Budaun	Block	Jagat
Gram Panchayat	-	Village	-
Habitation	School	Location	Zealot Public School Budaun.
Water Source	Submersible	Sample No.	09
Quantity of the Sample	1L	Date of Sample Collection	09/04/2024
Receiving Date	09/04/2024	Sample Collector	Vipin Kumar
Sample Depositor	Vipin Kumar		
Analysis Start Date	09/04/2024	Analysis Completion Date	10/04/2024

Environmental Condition

Temperature	25±3°C	Humidity	50±15%
-------------	--------	----------	--------


Technical Data of Analysis

S.No	Analysed Parameter	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Odour	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2018
2	Taste	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2018
3	pH @25°C	6.57	6.5-8.5	6.5-8.5	IS 3025(Part 11):2022Electrometric Method
4	Turbidity(NTU)	1.24	1	5	IS 3025 (Part 10):2023
5	Total DissolvedSolid (mg/L)	239	500	2000	IS 3025 (Part 16):2023
6	Chloride(mg/L)	14.96	250	1000	IS 3025(Part 32):2019
7	Total Alkalinity(mg/L)	35	200	600	IS 3025 (Part 23):2023
8	Total Hardness(mg/L)	149	300	600	IS 3025 (Part 21):2019
9	Calcium(mg/L)	29	75	200	IS 3025 (Part 40):2023

Note	1. This certificate refers only to the particular sample(s) submitted for testing.
	2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Head of the Laboratory.
	3. The Test results reported in this certificate are valid at the time of and under the stated conditions of Measurements.
	4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue .



* END OF REPORT *



Water Analysis Report

DISTRICT LEVEL WATER ANALYSIS LABORATORY, U.P JAL NIGAM (BUDAUN)

BACTERIOLOGICAL SAMPLE TEST REPORT

Report No.	09	Date	10/04/2024	Page No.	01
------------	----	------	------------	----------	----

Customer Details

Name & Address	Zealot Public School District Budaun Up. 620/011-Prayogshala/23 Dated 09/5/2023.
Ref Letter No.&Date	

Basic details of sample

District	Budaun	Block	Jagat-
Gram Panchayat	-	Village	-
Habitation	School	Location	Zealot Public School District Budaun Up
Water Source	Submersible	Sample No.	09
Quantity of Sample	1L	Date of Sample Collection Date	09/04/2024
Receiving Date	09/04/2024	Sample Collector	Vipin kumar
Analysis Start Date	09/04/2024	Analysis Completion Date	10/04/2024

Environmental Condition

Temperature	25±3°C	Humidity	50±15%
-------------	--------	----------	--------

Technical Data of Analysis

Sr.N o.		Units	Observed Value	Specified Values as per IS 10500:2021		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Total coliform	CFU	0.0	No Relaxation	0.0 CFU/100mL	APHA23 rd Edition:2017
2	E.Coli	CFU	0.0	No Relaxation	0.0 CFU/100mL	APHA23 rd Edition:2017

Note:-

- 1.This Certificate refers only to the particular sample(s) submitted for testing.
- 2.This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of laboratory.
3. The Test result reported in this certificate are valid at the time of and under the stated conditions of measurements
4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.

(SWATI PRIYADARSHI)
Result approved by
Laboratory Microbiologist